

耐熱電纜構造表

導體尺寸	心數	絕緣厚度	被覆厚度	約 計 完成外徑	最 大 導體電阻 (20°C)	試驗電壓	最 小 絕緣電阻 (20°C)	標準單長
mm	C	mm	mm	mm	Ω /Km	V/1min	MΩ Km	m
1.2	1	0.4	0.8	3.6	16.0	1500	50	300
1.2	2	0.5	1.0	6.5	16.0	1500	50	300
1.2	3	0.5	1.0	6.9	16.0	1500	50	300
1.2	4	0.5	1.0	7.4	16.0	1500	50	300
1.2	5	0.5	1.0	8.1	16.0	1500	50	300
1.2	6	0.5	1.0	8.7	16.0	1500	50	300
1.2	7	0.5	1.0	8.7	16.0	1500	50	300
1.6	1	0.4	0.8	4.0	9.01	1500	50	300
1.6	2	0.5	1.0	7.3	9.01	1500	50	300
1.6	3	0.5	1.0	7.7	9.01	1500	50	300
1.6	4	0.5	1.0	8.3	9.01	1500	50	300
1.6	5	0.5	1.0	9.1	9.01	1500	50	300
1.6	6	0.5	1.0	9.9	9.01	1500	50	300
1.6	7	0.5	1.0	9.9	9.01	1500	50	300
2.0	1	0.4	0.8	4.4	5.77	1500	50	300
2.0	2	0.5	1.0	8.1	5.77	1500	50	300
2.0	3	0.5	1.0	8.5	5.77	1500	50	300
2.0	4	0.5	1.0	9.3	5.77	1500	50	300
2.0	5	0.5	1.0	10.2	5.77	1500	50	300
2.0	6	0.5	1.0	11.1	5.77	1500	50	300
2.0	7	0.5	1.0	11.1	5.77	1500	50	300